



Water Supply District of Acton

693 MASSACHUSETTS AVENUE
P.O. BOX 953
ACTON, MASSACHUSETTS 01720

TELEPHONE (978) 263-9107

FAX (978) 264-0148

DATE: 10/7/2011

TO: Town of Acton Planning Department

FROM: Chris Allen, District Manager

RE: Comments on Duggan Farm Residential Compound off Arlington Street

1. All water mains, services, appurtenances and installation of such must comply with AWD specifications. (Hard copy may be picked up at AWD main office)
2. As shown, water service will be via a common 4" Ductile Iron (DI) line. Each residential water service will have a curb stop isolation installed, not shown.
3. Any existing services being abandoned will be shut off at the water main in the public way. Not "Cut & capped" as annotated on the proposed "As-built".
4. All installed infrastructure must be inspected by AWD personnel prior to backfill.
5. A final "As-Built" plan denoting exact locations of all water infrastructure will be submitted by the contractor prior to filling of any water mains for pressure test or disinfection per AWD specifications.

Respectfully submitted

Chris Allen
District Manager